


RESTRICTIVE NOTICE: These designs and drawings were prepared by Jefferson Science Associates, LLC, hereinafter the Contractor, under Contract No. DE-AC05-06OR22077 with the Department of Energy (DOE). All rights in the designs and drawings are reserved by DOE. No part of these designs or drawings are to be released or distributed to the public. NEITHER THE GOVERNMENT NOR THE CONTRACTOR MAKES ANY WARRANTY, EXPRESS OR IMPLIED, OR ASSUMES ANY LIABILITY FOR THE USE OF THESE DESIGNS OR DRAWINGS. (This notice including this sentence must appear on any copies of these designs or drawings.)

8 7 6 5 4 3 2 1

| REVISION HISTORY | | | | | |
|--------------------|-----|---|------------------------|-----------|--|
| ZONE | REV | DESCRIPTION | DATE | APPROVED | |
| ALL | - | INITIAL SUBMITTAL | TMM 30AUG17 30AUG17 | R. NORTON | |
| ALL | A | 1. DRAWING REVISED IN ITS ENTIRETY. | TMM 29SEP17 29SEP17 | R. NORTON | |
| SH1 SH2 SH2 | B | 1. REVISED ITEM QUANTITY. 2. CHANGED THE PART NUMBER & LABEL. 3. REMOVED C34 CIRCUIT BREAKER AND REVISED NUMBERING. | 30JAN18 | R. NORTON | |
| SH1 C-3 SH1 C-3 | | 4. ADDED ITEM 19 TO PART LIST AND BODY OF THE DRAWING. 5. REVISED QUANTITY FOR ITEM 3, 7, 16. | | | |
| SS | | | SS 30JAN18 | | |
| SH2 A-4 | C | 1. ADDED CB36, 37. | CRS 20MAR18 30JAN18 | R. NORTON | |

| | | | | | | |
|---|-----|----|--------------------------------|--|---------------|--------|
| B | 2 | 19 | WAGO 284-687 | 3-CONDUCTOR GROUND TERMINAL BLOCK | - | - |
| | A/R | 18 | GENERIC | LABEL, ENGRAVED OR PRINTED | TEXT AS SHOWN | NOTE 2 |
| B | 4 | 17 | WAGO 284-308 | END AND INTERMEDIATE PLATE; 2.5 MM THICK | - | - |
| | 4 | 16 | WAGO 284-681 | 3-CONDUCTOR THROUGH TERMINAL BLOCK | - | - |
| | 3 | 15 | ALLEN-BRADLEY 1492-SPM1B020 | SINGLE POLE 2 AMP CIRCUIT BREAKER, TRIP CURVE B | - | - |
| | 3 | 14 | WAGO 870-557 | GROUND TERMINALS, SPRING CLAMP, THREE LEVEL | - | - |
| | 1 | 13 | ALLEN-BRADLEY 1492-SPM1B200 | SINGLE POLE 20 AMP CIRCUIT BREAKER, TRIP CURVE B | - | - |
| | 4 | 12 | WAGO 249-116 | END STOP | - | - |
| | 1 | 11 | HOFFMAN ATEMND | FAN THERMOSTAT | - | - |
| | 1 | 10 | WAGO 870-410 | PLUG IN CENTER JUMPER | - | - |
| | 8 | 9 | WAGO 870-568 | END BARRIER | - | - |
| | A/R | 8 | WAGO 210-112 | 35MM X 7.5MM DIN RAIL | - | - |
| B | 8 | 7 | ALLEN-BRADLEY 1492-SPM1B050 | SINGLE POLE 5 AMP CIRCUIT BREAKER, TRIP CURVE B | - | - |
| | 11 | 6 | ALLEN-BRADLEY 1492-SPM1B010 | SINGLE POLE 1 AMP CIRCUIT BREAKER, TRIP CURVE B | - | - |
| | 16 | 5 | WAGO 870-556 | TERMINALS, SPRING CLAMP, THREE LEVEL | - | - |
| | 1 | 4 | WAGO 787-885 | 24V, 20A POWER SUPPLY REDUNDANCY MODULE WITH CAGE CLAMP TERMINALS | - | - |
| | 5 | 3 | ALLEN-BRADLEY 1492-SPM1B100 | SINGLE POLE 10 AMP CIRCUIT BREAKER, TRIP CURVE B | - | - |
| | 2 | 2 | WAGO 787-1634 | POWER SUPPLY, 24VDC, 480W METALLIC CASE, CAGE CLAMP TERMINALS | - | - |
| | 2 | 1 | ALLEN-BRADLEY 1492-SPM1B160 | SINGLE POLE 16 AMP CIRCUIT BREAKER, TRIP CURVE B | - | - |
| | | | | | | |


| PARTS LIST | | MATERIAL | | NOTES | |
|--|------------|--------------------------|----------|--------------------------------|------|
| EACH SHEET OF A MULTI-SHEET DRAWING SHALL ALWAYS CARRY THE SAME REVISION LEVEL | | SEE PARTS LIST | | UNLESS OTHERWISE SPECIFIED | |
| DIM & TOL PER ASME Y14.5-2009 UNLESS OTHERWISE SPECIFIED | | FINISH MACHINED SURFACES | | UNLESS OTHERWISE NOTED | |
| DIMENSIONS ARE IN INCHES | | N/A | | REBURR & BREAK ALL SHARP EDGES | |
| TOLERANCES ARE: | | DO NOT SCALE DRAWING | | SCALE | |
| FRACTIONS | DECIMAL | ANGLES | SIZE | DWG. NO. | REV |
| + 1/8 | X ± .1 | + .50° | D | 79221-1001 | C |
| XX ± .01 | XXX ± .005 | | SCALE | NONE | |
| | | | DATE | 30AUG17 | |
| | | | DRAWN | T.MCCOOL | |
| | | | DATE | 30AUG17 | |
| | | | SCALE | NONE | |
| | | | DATE | 30AUG17 | |
| | | | DWG. NO. | 79221-1000 | |
| | | | SHEET | 1 | OF 2 |



NOTE:
 1. LINE, NEUTRAL AND GROUND TERMINAL BLOCK LAYOUT APPLIES TO ALL TB1-1 THRU TB1-9.
 2. WHERE NEEDED USE HARDMAN #4001 (OR EQUAL) TO ADHERE LABELS.

8 7 6 5 4 3 2 1

RESTRICTIVE NOTICE: These designs and drawings were prepared by Jefferson Science Associates, LLC, hereinafter the Contractor, under Contract No. DE-AC05-06OR22377 with the Department of Energy (DOE). All rights in the designs and drawings are reserved by DOE. In behalf of the United States Government and the Contractor as provided in the Contract. You are authorized to use these works for Governmental purposes but it is not to be released or distributed to the public. NEITHER THE GOVERNMENT NOR THE CONTRACTOR MAKES ANY WARRANTY, EXPRESS OR IMPLIED, OR ASSUMES ANY LIABILITY FOR THE USE OF THESE DESIGNS OR DRAWINGS. (This notice including this sentence must appear on any copies of these designs or drawings.)



| | | |
|-------|------------|--------|
| SIZE | DWG. NO. | REV. |
| D | 79221-1001 | C |
| SCALE | DATE | SHEET |
| NONE | 79221-1000 | 2 OF 2 |